

Compliance Certificate - CR-22-12

Envirowall System (3.0 m high Floor to Ceiling)

The Protecta Envirowall free standing hoarding system has been tested for compliance to AS 4687 *Temporary fencing and hoardings*, for a hoarding height of 3000 mm fixed top and bottom for impact loading with impacts in locations as defined in the standards,.


Impact testing was conducted at Protecta Group Australia Pty Ltd
 13 Rachael Close
 Silverwater, NSW 2128

The test results detailed in Test Report ABES-TR-22-05, confirm that Protecta Group, Envirowall configuration of three (3) panels installed in a fixed top and fixed bottom track, between joined with a spacing of 1.2 m, meet the minimum performance requirements as specified in Section 3.3.4 (a) and (b) of AS 4687.1-2022 Temporary fencing and hoardings, specifically testing in accordance with **4687.3-2022 Appendix B Impact testing.**

Testing of the Envirowall panels for infill rigidity to prevent ballistic penetrations from nail or screws or other airborne building shrapnel from passing through the panel are also details and it is considered that the panel demonstrate the required rigidity to prevent the passing of errant projectiles as required by **4687.3 Clause 2.5.**

The Impact test results are conditional with the hoarding being installed in accordance with the manufactures guidelines and as detailed in this compliance Report.

The compliance certificate is valid for meeting the requirements of the tests and clauses listed, assessment of the stability of the wall system under lateral wind load if required should be conducted prior to installation.



5/09/22
Andrew Wheeler
PhD BE(Hons) FIEAust CPEng NER APEC Engineer IntPE(Aus)
RPEQ 18304, PRE1151 (NSW), PE3052 (VIC)